



Facilities Management
Design & Construction

Deviation Request Number: _____

DEVIATION REQUEST FORM

This form shall be used by Design Professional to request a deviation from the Design Standards & Procedures and must be completed prior to bid document phase. Please complete and return via email to the UI Project Manager in .pdf format.

Date: _____ Project Phase: _____
(SD, DD, CD)

UI Project Name: _____

UI Project Number: _____ Owner's Design Project Manager: _____

Design Professional: _____

Design Professional Representative: _____
(first and last name)

Email Address: _____ Phone: _____

Design Standards Edition: July 31, 2020 Section Number: Section III, 6.1.10 Page Number: 161

Description of Deviation: (attach additional page(s) as needed)

Variable frequency drives will not be provided with cards for BACnet integration; software points available from
Variable frequency drives will not be mapped to the Building Automation System

Justification for Deviation Request: (attach additional page(s) as needed)

The available data is currently not utilized. The card and capability can be added at a later date as needed.

Attachment List: None Total number of pages attached: None

Reviewed / Approved By:

(Responses NA – not applicable, R&A – reviewed & approved, RAN – reviewed as noted, R&R – revise & resubmit, NR – not recommended):

10/5/2020	10/7/2020	10/15/2020	10/15/2020
1) Public Safety	2) B&LS	3) UI Utilities	4) FIMS
DocuSigned by: (Department Name) <u>David Visin</u> NA Response 46E213DE3FFA4B0... (Printed Name & Initial)	DocuSigned by: (Department Name) <u>Julie Sychra</u> R&A Response DE83468DF7E409... (Printed Name & Initial)	DocuSigned by: (Department Name) <u>Ben Fish</u> R&A Response 5B9D22E0F4144A2... (Printed Name & Initial)	DocuSigned by: (Department Name) <u>Kirk Banks</u> NA Response E09416D3DA0D4A4... (Printed Name & Initial)
5) (Department Name) Response (Printed Name & Initial)	6) (Department Name) Response (Printed Name & Initial)	7) (Department Name) Response (Printed Name & Initial)	8) (Department Name) Response (Printed Name & Initial)

(B&LS, UIU (Ben Fish), Public Safety and FIMS required for all main campus deviations. Capital Management, Engineering Services required for all UIUC deviations. Include all other departments/stakeholders impacted: P&T, ITS, Campus Planning, Safety & Security, HCIS, etc.)

Chet Wieland 10/15/2020
E36A1D184E9949B...